



**CITY OF ASHEBORO  
SYSTEM PERFORMANCE REPORT  
JANUARY 1, 2015 - DECEMBER 31, 2015**

THIS REPORT IS COMPILED AND SUBMITTED IN ACCORDANCE  
WITH HOUSE BILL 1160 – CLEAN WATER ACT OF 1999.

CITY OF ASHEBORO  
DIVISION OF WATER RESOURCES  
WASTEWATER TREATMENT DEPARTMENT  
POST OFFICE BOX 1106  
ASHEBORO, NORTH CAROLINA 27204-1106

Contact Person:

Mr. John Ogburn, City Manager  
Post Office Box 1106  
Asheboro, North Carolina 27204-1106  
Phone: (336) 626-1200

Wastewater Treatment Plant  
Operator In Responsible Charge:  
Mr. Michael Ray Wiseman  
Phone: (336) 672-0892, Ext. 211

Systems Maintenance  
Operator In Responsible Charge:  
Mr. Jeffrey Dean Cagle  
Phone: (336) 672-0892, Ext, 205

Water/Sewer Maintenance Superintendent  
Operator In Responsible Charge:  
Mr. Andrew Connor  
Phone: (336) 626-1234, Ext. 2201

Assistant Water/Sewer Maintenance Superintendent  
Back up ORC:  
Mr. David Johnson  
Phone: (336) 626-1234, Ext. 2205

Mailing Address:  
PO Box 1106  
Asheboro, NC 27204

Phone: 336-626-1201  
Fax: 336-626-1218  
[www.asheboronc.gov](http://www.asheboronc.gov)

Physical Address:  
146 North Church Street  
Asheboro, NC 27203

**CITY OF ASHEBORO ANNUAL  
SYSTEM PERFORMANCE REPORT  
PAGE -2-**

Water/Sewer Maintenance  
Back up ORC:  
Mr. Shannon White  
Phone: (336) 963-8797

Water/Sewer Maintenance  
Back up ORC:  
Mr. Robbie Shortridge  
Phone: (336) 626-1234, Ext. 2204

Water/Sewer Maintenance  
Back up ORC:  
Mr. Louis Bivins  
Phone: (336) 301-5198

Public Works Director  
Operator In Responsible Charge:  
Mr. David Hutchins  
Phone: (336) 626-1234, Ext. 2202

**APPLICABLE PERMITS:**

NPDES Permit No. NC0026123

Wastewater Collection System Permit No. WQCS00025

**COLLECTION SYSTEM PROCESS:**

Gravity Collection System – 205.6 Miles  
Force Main – 25.7 Miles

**LIFT STATIONS:** 24

**TREATMENT PLANT SYSTEM:**

Includes: Preliminary treatment, primary treatment, biological trickling filters, secondary treatment, nitrification aeration, final clarification, sand filters, chlorination, disinfection and dechlorination.

**TREATMENT PLANT PERFORMANCE**

During the twelve-month period from January 1, 2015 through December 31, 2015, total flow for the wastewater treatment plant was 1,396,433,000 gallons.

**CITY OF ASHEBORO ANNUAL  
SYSTEM PERFORMANCE REPORT  
PAGE -3-**

During the period from January 1, 2015 through December 31, 2015, the City of Asheboro experienced three (3) overflow events at the Wastewater Treatment Plant, fourteen (14) overflow events from lift stations and eighteen (18) overflow events from the collection system. This amounted to a total of 810,233 gallons from the wastewater treatment plant, 425,230 gallons from lift stations, and 246,240 gallons overflowing from manholes, which represents only 0.11 percent of the total flow treated for this calendar year.

**WASTEWATER TREATMENT PLANT**

April 14, 2015	1,000 Gallons
September 28, 2015	900 Gallons
December 30, 2015	808,333 Gallons

**LIFT STATIONS:**

October 03, 2015	8,890 Gallons	Lift Station #3 – 1129 E. Mine Street - NOV
October 03, 2015	15,720 Gallons	Lift Station #6 – 15 Richland Place - NOV
October 03, 2015	2,060 Gallons	Lift Station #3 – 1129 E. Mine Street - NOV
November 02, 2015	13,500 Gallons	Lift Station #3 – 1129 E. Mine Street – NOV
November 02, 2015	490 Gallons	Lift Station #6 – 15 Richland Place – NOV
November 09, 2015	17,825 Gallons	Lift Station #3 – 1129 E. Mine Street – NOV
November 19, 2015	51,745 Gallons	Lift Station #6 – 15 Richland Place – NOV
November 19, 2015	450 Gallons	Lift Station #3 – 1129 E. Mine Street – NOV
December 22, 2015	6,400 Gallons	Lift Station #3 – 1129 E. Mine Street – NOV
December 22, 2015	76,600 Gallons	Lift Station #6 – 15 Richland Place – NOV
December 23, 2015	2,025 Gallons	Lift Station #3 – 1129 E. Mine Street – NOV
December 30, 2015	48,000 Gallons	Lift Station #3 – 1129 E. Mine Street – NOV
December 30, 2015	173,525 Gallons	Lift Station #6 – 15 Richland Place – NOV
December 30, 2015	8,000 Gallons	Lift Station #2 – 1229 E. Dixie Drive – NOV

**CITY OF ASHEBORO ANNUAL  
SYSTEM PERFORMANCE REPORT**

PAGE -4-

**COLLECTION SYSTEM: (ALL THE FOLLOWING OVERFLOW EVENTS WERE  
FROM MANHOLES)**

February 26, 2015	6,870 Gallons	2314 Regency Drive – NOV
March 18, 2015	4,200 Gallons	1901 North Fayetteville Street - NOV
October 12, 2015	3,150 Gallons	Service Line at 427 S. Main Street – NOV
November 02, 2015	1,325 Gallons	Manhole #2501 @ 225 E. Ward Street – NOV
November 02, 2015	4,500 Gallons	720 W. Kivett Street - NOV
November 02, 2015	36,900 Gallons	Landsdown Lake Lane – NOV
November 09, 2015	2,125 Gallons	501 Meadowbrook Road – NOV
November 09, 2015	128,250 Gallons	Cheddington & Landsdown Lake Lane – NOV
November 19, 2015	7,500 Gallons	951 Central Falls Road – NOV
December 01, 2015	300 Gallons	WWTP – 1032 Bonkemeyer Drive
December 17, 2015	3,600 Gallons	426 Greenlawn Drive – NOV
December 22, 2015	2,250 Gallons	1356 Ridgewood Circle – NOV
December 23, 2015	14,400 Gallons	951 Central Falls Road – NOV
December 23, 2015	4,875 Gallons	577 Old Lexington Rd – NOV
December 24, 2015	10,250 Gallons	Northeast Outfall @ Haskett’s Creek – NOV
December 30, 2015	8,500 Gallons	Sky Drive and W. Bailey Street – NOV
December 30, 2015	9,270 Gallons	951 Central Falls Road – NOV
December 30, 2015	12,000 Gallons	Glenwood Road and Redding Road – NOV

City of Asheboro drinking water was not affected by any of these overflow events. Necessary measures were taken by both Water/Sewer Maintenance and Systems Maintenance personnel to address, correct, and minimize these overflow events. The Division of Water Resources in Winston-Salem was notified of each of these overflow events.